

Confirmation for TFI Report 24-000821-01

Test order

Emission testing according to the French regulation on VOC "Décret no 2011-321" dated 23 March, 2011 (according to EN 16516, ISO 16000 series principles)

Customer

dBcover Solutions S.L.
Av. Benelux 91 P.I.C.A.
3600 Elda
ES

Tested product

HARMONIUM PET

Parameter	CAS no.	Result ¹ [µg/m³]	Requirements for class A + [µg/m³]	Fulfilled
Formaldehyde ¹	50-00-0	< 2	< 10	Yes
Acetaldehyde ¹	75-07-0	< 2	< 200	Yes
Toluene	108-88-3	< 2	< 300	Yes
Tetrachloroethylene	127-18-4	< 2	< 250	Yes
Xylene	1330-20-7	< 2	< 200	Yes
1,2,4-Trimethylbenzene	95-63-6	< 2	< 1000	Yes
1,4-Dichlorobenzene	106-46-7	< 2	< 60	Yes
Ethylbenzene	100-41-4	< 2	< 750	Yes
2-Butoxyethanol	111-76-2	< 2	< 1000	Yes
Styrene	100-42-5	< 2	< 250	Yes
CMR ³	-	each < 1	each < 1	Yes
TVOC [toluene equivalent acc. ISO 16000-6]	-	10	< 1000	Yes

¹ Testing after 28 days

³ according to French CMR Regulation (30 April 2009)

The measurement results are evaluated without consideration of the measurement uncertainty with reference to compliance with limit values, unless otherwise specified by the test standard.

Classification according to the French regulation on VOC


Aachen, 5 November 2024



Dr. Andreas Zoëga
- head of testing laboratory -

Norbert Beckers

The present document is provided with an advanced electronic signature.